

## KEMA TEST REPORT

1186-18

<b>Object</b>	Single-core power cable
<b>Type</b>	U <sub>0</sub> = 12 kV 1x240 mm <sup>2</sup> XLPE CABLE  12/20 (24) kV - 1x240 mm <sup>2</sup> - Cu - XLPE - LSHOF
<b>Client</b>	Metal Cable Co., No. 41, Hosseini Rad Alley, Motahari Coner, Valiasr Ave. 1595814613 Tehran, Iran
<b>Manufacturer</b>	Metal Cable Co., No. 41, Hosseini Rad Alley, Motahari Coner, Valiasr Ave. 1595814613 Tehran, Iran *)
<b>Tested by</b>	DNV GL Netherlands B.V., Arnhem, the Netherlands
<b>Date of tests</b>	13 March to 26 May 2018
<b>Test specification</b>	The tests have been carried out in accordance with client's instructions. Test procedure and test parameters were based on IEC 60502-1:2004+AMD1:2009 and IEC 60502-2:2014.
<b>Summary and conclusion</b>	See chapter 1 for test specifications and results.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

\*) as declared by the client

This report consists of 42 pages in total.

DNV GL Netherlands B.V.



J.P. Fonteijne  
Executive Vice President  
KEMA Laboratories



Laboratories

Arnhem, 27 August 2018

## INFORMATION SHEET

### 1 KEMA Type Test Certificate

A KEMA Type Test Certificate contains a record of a series of (type) tests carried out in accordance with a recognized standard. The equipment tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by DNV GL. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The Certificate contains the essential drawings and a description of the equipment tested. A KEMA Type Test Certificate signifies that the object meets all the requirements of the named subclauses of the standard. It can be identified by gold-embossed lettering on the cover and a gold seal on its front sheet.

The Certificate is applicable to the equipment tested only. DNV GL is responsible for the validity and the contents of the Certificate. The responsibility for conformity of any object having the same type references as the one tested rests with the manufacturer.

Detailed rules on types of certification are given in DNV GL's Certification procedure applicable to KEMA Laboratories.

### 2 KEMA Report of Performance

A KEMA Report of Performance is issued when an object has successfully completed and passed a subset (but not all) of test programmes in accordance with a recognized standard. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The report is applicable to the equipment tested only. A KEMA Report of Performance signifies that the object meets the requirements of the named subclauses of the standard. It can be identified by silver-embossed lettering on the cover and a silver seal on its front sheet.

The sentence on the front page of a KEMA Report of Performance will state that the tests have been carried out in accordance with ..... The object has complied with the relevant requirements.

### 3 KEMA Test Report

A KEMA Test Report is issued in all other cases. Reasons for issuing a KEMA Test Report could be:

- Tests were performed according to the client's instructions.
- Tests were performed only partially according to the standard.
- No technical drawings were submitted for verification and/or no assessment of the condition of the test object after the tests was performed.
- The object failed one or more of the performed tests.

The KEMA Test Report can be identified by the grey-embossed lettering on the cover and grey seal on its front sheet.

In case the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer, the following sentence will appear on the front sheet. The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on ..... If the object does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on client's request.

When the tests, test procedure and/or test parameters are not in accordance with a recognized standard, the front sheet will state the tests have been carried out in accordance with client's instructions.

### 4 Official and uncontrolled test documents

The official test documents of DNV GL are issued in bound form. Uncontrolled copies may be provided as loose sheets or as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

**TABLE OF CONTENTS**

1	Test specifications and results.....	5
2	Identification of the object tested.....	6
2.1	Ratings/characteristics of the object tested	6
2.2	Description of the object tested	6
2.3	List of drawings	8
3	General information.....	9
3.1	The tests were witnessed by	9
3.2	The tests were carried out by	9
3.3	Subcontracting	9
3.4	Purpose of the tests	9
3.5	Measurement uncertainty	9
4	Electrical type tests.....	10
4.1	Test arrangement	10
4.1.1	Determination of the cable conductor temperature	10
4.1.2	Photograph of test set-up	11
4.2	Bending test	12
4.3	Partial discharge test	13
4.4	Tan $\delta$ measurement	14
4.5	Heating cycle test	15
4.6	Partial discharge test	16
4.7	Impulse test	17
4.8	Voltage test for 15 min	20
4.9	Voltage test for 4 h	21
4.10	Resistivity of semi-conducting screens	22
5	Non-electrical type tests.....	23
5.1	Measurement of thickness of insulation	23
5.2	Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)	24
5.3	Tests for determining the mechanical properties of insulation before and after ageing	25
5.4	Additional ageing test on pieces of completed cable	26
5.5	Test on PVC insulation and sheaths at low temperature	27
5.6	Hot set test for XLPE insulation and elastomeric sheaths	28
5.7	Water absorption test on insulation	29
5.8	Flame spread on single cable	30
5.9	Shrinkage test for XLPE insulation	31
6	Check of cable construction.....	32

7	Additional tests .....	33
7.1	Water absorption test on oversheath	33
7.2	Pressure test at high temperature on insulation and non-metal sheaths	34
7.3	Flame spread test on bunched cables	35
7.4	Smoke emission test	36
7.5	Tests for determining the mechanical properties of non-metal sheaths before and after ageing	37
7.6	Acid gas emission test	38
7.7	pH and conductivity test	39
7.8	Fluorine content test	40
8	Data sheet .....	41
9	Measurement uncertainty .....	42

## 1 TEST SPECIFICATIONS AND RESULTS

According to the client's instruction the following tests have been performed.

Test	Specification	Clause	Deviation	Test result
Determination of the cable conductor temperature	IEC 60502-2	15.4	-	passed
Bending test	IEC 60502-2	18.2.4	-	passed
Partial discharge test	IEC 60502-2	18.2.5	-	passed
Tan $\delta$ measurement	IEC 60502-2	18.2.6	-	passed
Heating cycle test	IEC 60502-2	18.2.7	-	passed
Partial discharge test	IEC 60502-2	18.2.5	-	passed
Impulse test	IEC 60502-2	18.2.8	-	passed
Voltage test for 15 min	IEC 60502-2	18.2.8	-	passed
Voltage test for 4 h	IEC 60502-2	18.2.9	-	passed
Resistivity of semi-conducting screens	IEC 60502-2	18.2.10	-	passed
Measurement of thickness of insulation	IEC 60502-2	19.2	-	passed
Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)	IEC 60502-2	19.3	-	passed
Tests for determining the mechanical properties of insulation before and after ageing	IEC 60502-2	19.5	-	passed
Additional ageing test on pieces of completed cable	IEC 60502-2	19.7	-	passed
Additional ageing test on pieces of completed cable	IEC 60502-1	18.5	-	passed
Test on PVC insulation and sheaths at low temperature	IEC 60502-1	18.8	-	passed
Hot set test for XLPE insulation and elastomeric sheaths	IEC 60502-2	19.13	-	passed
Water absorption test on insulation	IEC 60502-2	19.15	-	passed
Flame spread on single cable	IEC 60502-2	19.16	-	passed
Shrinkage test for XLPE insulation	IEC 60502-2	19.18	-	passed
Check of cable construction	IEC 60502-2	5-14	-	passed
Water absorption test on oversheath	IEC 60502-1	18.13	-	passed
Pressure test at high temperature on insulation and non-metal sheaths	IEC 60502-1	18.7	-	passed
Flame spread test on bunched cables	IEC 60332-3-24	Category C	-	passed
Smoke emission test	IEC 61034-2	-	-	passed
Tests for determining the mechanical properties of non-metal sheaths before and after ageing	IEC 60502-1	18.4	-	passed
Acid gas emission test	IEC 60754-1	-	-	passed
pH and conductivity test	IEC 60754-2	-	-	passed
Fluorine content test	IEC 60684-2	-	-	passed

## 2 IDENTIFICATION OF THE OBJECT TESTED

### 2.1 Ratings/characteristics of the object tested

Rated voltage, $U_0/U (U_m)$	12/20 (24) kV
Rated maximum conductor temperature in normal operation	90 °C
Rated conductor cross-section	240 mm <sup>2</sup>

### 2.2 Description of the object tested

Standard	IEC 60502-2, Clause 5-14
Manufacturer	Metal Cable Co., Saveh, Iran
Type	$U_0 = 12$ kV 1x240 mm <sup>2</sup> XLPE CABLE
Manufacturing year	2017
Quantity submitted	62 m
Rated voltage, $U_0/U (U_m)$	12/20 (24) kV
Nominal capacitance between conductor and metal screen	0,3 µF/km
No. of cores	1
Overall diameter	38,6 mm
Marking on the oversheath	Metal Cable CO. IEC 60502-2 CU/SC/XLPE/SC/SCT/(CWS+CTS)/LSFOH(N2XSH) 1*240/25 SQMM 12/20(24)KV MADE IN IRAN 164-2 2017

#### Conductor

• material	copper
• cross-section	240 mm <sup>2</sup>
• nominal diameter	18,4 mm
• type	compacted
• maximum conductor temperature in normal operation	90 °C
• presence and nature of measures to achieve longitudinal watertightness	no
• swelling material	known in KEMA Laboratories' files
• manufacturer of the material	known in KEMA Laboratories' files

#### Conductor screen

• material	semi-conducting PE
• nominal thickness	0,7 mm
• material designation	known in KEMA Laboratories' files
• manufacturer of the material	known in KEMA Laboratories' files

**Insulation**

- material XLPE
- nominal thickness 5,5 mm
- nominal inner diameter of the insulation 20 mm
- nominal outer diameter of the insulation 31 mm
- material designation known in KEMA Laboratories' files
- manufacturer of the material known in KEMA Laboratories' files

**Insulation (core) screen**

- material semi-conduction PE
- strippable no
- nominal thickness 0,5 mm
- material designation known in KEMA Laboratories' files
- manufacturer of the material known in KEMA Laboratories' files

**Metal screen**

- material copper wires, 1 layer tape
- number of wires/tapes 43 wires and 1 tape
- thickness and width of binder tapes 0,1 x 10 mm (gap 135 mm)
- nominal diameter of wires 0,86 mm
- cross-sectional area 25 mm<sup>2</sup>

**Oversheath**

- material halogen free type ST<sub>8</sub>
- nominal thickness 2,2 mm
- nominal overall diameter of the cable (D) 38,6 mm
- material designation known in KEMA Laboratories' files
- manufacturer of the material known in KEMA Laboratories' files
- colour red
- graphite coating applied no

**Fire retardant** (according to IEC 60332-1) yes

**Manufacturing details insulation system**

- location of manufacturing Saveh, Iran
- type of extrusion line CCV
- type of extrusion triple common extrusion
- factory identification of extrusion line Maillefer
- manufacturer of the extrusion line known in KEMA Laboratories' files
- identification of production batch WC505406-021 2016-08-15
- curing means N<sub>2</sub>
- cooling means water
- manufacturing length (where cable sample for testing has been taken from) 500 m
- length markings on cable sample sent to KEMA Laboratories begin: 371 m, end: 433 m

## 2.3 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following document. KEMA Laboratories has verified that these drawings and/or documents adequately represent the object tested. The manufacturer is responsible for the correctness of these drawings and/or documents and the technical data presented.

The following document has been included in this report:

Drawing no./document no.

MC - 18641

Revision

3 May 2017



## 3 GENERAL INFORMATION

### 3.1 The tests were witnessed by

The tests were carried out without a representative of the client present.

### 3.2 The tests were carried out by

<b>Name</b>	<b>Company</b>
J. Mooren	DNV GL Netherlands B.V.,
I. Chatzis	Arnhem, the Netherlands

### 3.3 Subcontracting

The following tests were subcontracted to DNV GL / Energy Advisory, MTL Laboratory:

- measurement of resistivity of semi-conducting screens in accordance with subclause 18.2.10.
- non-electrical type tests in accordance with clause 19.
- check of cable construction in accordance with clauses 5 to 14.

The following tests were subcontracted to BRE Global Ltd., Watford, Herts, United Kingdom.

- measurement of smoke emission in accordance with IEC 61034-2
- measurement of flame propagation on multiple cables in accordance with IEC 60332-3-24.

The following tests were subcontracted to ISQ-LABQUI, Portugal

- measurement of pH and conductivity test in accordance with IEC 60754-2
- measurement of acid gas emission test in accordance with IEC 60754-1
- measurement of fluorine test in accordance with IEC 60684-2.

### 3.4 Purpose of the tests

Purpose of the tests was to verify whether the material complies with the specified requirements.

### 3.5 Measurement uncertainty

A table with measurement uncertainties is enclosed in this report. Unless otherwise stated, the measurement uncertainties of the results presented in this report are as indicated in that table.

## 4 ELECTRICAL TYPE TESTS

### 4.1 Test arrangement

#### 4.1.1 Determination of the cable conductor temperature

**Standard**


Standard IEC 60502-2, subclause 15.4

For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the test loop in order to create the same environmental conditions as for the test loop.

The heating currents in the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. Annex G was used as a guide and Annex G, subclause G.3.1, method 1 was applied.

The tests at elevated temperature are carried out after the conductor temperature has been within the stated limit for at least 2 hours.

#### 4.1.2 Photograph of test set-up



## 4.2 Bending test

### Standard and date

Standard IEC 60502-2, subclause 18.2.4  
Test date 13 March 2018

### Environmental conditions

Ambient temperature 6 °C

### Characteristic test data

Temperature of test object 25 °C  
Maximum bending diameter  $20(d + D) + 5\%$   
Length of cable bended 62 m  
Length marking of cable bended 371 - 432

Actual external diameter of cable D mm	Actual diameter of cable conductor d mm	Maximum bending diameter D <sub>r</sub> mm	Diameter of test cylinder D <sub>t</sub> mm
39,0	18,4	1205	1150

### Result

The test was carried out successfully.

### 4.3 Partial discharge test

#### Standard and date

Standard IEC 60502-2, subclause 18.2.5  
 Test date 21 March 2018

#### Environmental conditions

Ambient temperature 20 °C

#### Characteristic test data

Temperature of test object 20 °C  
 Circuit direct  
 Calibration 10 pC  
 Noise level at 1,73 U<sub>0</sub> 2,0 pC  
 Declared sensitivity 3 pC  
 Required sensitivity ≤ 5 pC  
 Centre frequency 315 kHz  
 Bandwidth (Δf) 100 kHz  
 Test frequency 50 Hz  
 Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	... x U <sub>0</sub>	kV		
1	2	24	10	-
	1,73	20,8	-	Not detectable

#### Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,73 U<sub>0</sub>.

#### Result

The object passed the test.

## 4.4 Tan $\delta$ measurement

### Standard and date

Standard IEC 60502-2, subclause 18.2.6

Test date 22 March 2018

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Temperature of test object 97 °C

Length of test object 18,30 m

Standard capacitor 99,88 pF

Core	Voltage applied, 50 Hz kV	Capacitance of core <sup>1)</sup> $\mu\text{F}/\text{km}$	Tan $\delta$
1	5	0,273	$7,6 \times 10^{-4}$

<sup>1)</sup> for information only

### Requirement

The measured value shall not be higher than  $40 \times 10^{-4} \geq 2$  kV.

### Result

The object passed the test.

## 4.5 Heating cycle test

### Standard and date

Standard IEC 60502-2, subclause 18.2.7  
 Test date 23 to 30 March 2018

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Heating method conductor current  
 Stabilized temperature 97 °C

No. of heating cycles	Required steady conductor temperature °C	Heating current during steady condition A	Heating cycle		
			Heating		Cooling
			Total duration h	Duration of conductor at steady temperature h	Total duration h
20	95 - 100	approx. 889	8	2	3

### Requirement

The test shall be carried out successfully.

### Result

The object passed the test.

## 4.6 Partial discharge test

### Standard and date

Standard IEC 60502-2, subclause 18.2.5  
 Test date 30 March 2018

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Temperature of test object 20 °C  
 Circuit direct  
 Calibration 10 pC  
 Noise level at 1,73 U<sub>0</sub> 2,5 pC  
 Declared sensitivity 5 pC  
 Required sensitivity ≤ 5 pC  
 Centre frequency 100 kHz  
 Bandwidth (Δf) 100 kHz  
 Test frequency 50 Hz  
 Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration	Partial discharge level
	... x U <sub>0</sub>	kV		
1	2	24	10	-
	1,73	20,8	-	Not detectable

### Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,73 U<sub>0</sub>.

### Result

The object passed the test.



## 4.7 Impulse test

### Standard and date

Standard IEC 60502-2, subclause 18.2.8

Test date 3 April 2018

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Temperature of test object 97 °C

Specified test voltage 125 kV

Testing arrangement		Polarity	Voltage applied (% of test voltage)	No. of impulses	See figure on next pages
Voltage applied to	Earthed				
Conductor	Metal screen	Positive	50	1	1 (waveshape)
			65	1	2
			80	1	2
			100	10	3 and 4
Conductor	Metal screen	Negative	50	1	5 (waveshape)
			65	1	6
			80	1	6
			100	10	7 and 8

### Requirement

The cable core shall withstand without failure 10 positive and 10 negative voltage impulses.

### Result

The object passed the test.

### Lightning impulse test with positive voltage




Fig. 1: Waveshape 72127508 Metal cable 50% of test voltage




Fig. 2: 72127508 Metal cable 65% and 80% of test voltage




Fig. 3: 72127508 Metal cable 100% of test voltage




Fig. 4: 72127508 Metal cable 100% of test voltage

Lightning impulse test with negative voltage




Fig. 5: Waveshape 72127508 Metal cable -50% of test voltage




Fig. 6: 72127508 Metal cable -65% and -80% of test voltage




Fig. 7: 72127508 Metal cable -100% of test voltage




Fig. 8: 72127508 Metal cable -100% of test voltage

## 4.8 Voltage test for 15 min

### Standard and date

Standard IEC 60502-2, subclause 18.2.8

Test date 4 April 2018

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration min
Voltage applied to	Earth connected to	... x U <sub>0</sub>	kV	
Conductor	Metal screen	3,5	42	15

### Requirement

No breakdown of the insulation shall occur.

### Result

The object passed the test.

## 4.9 Voltage test for 4 h

### Standard and date

Standard IEC 60502-2, subclause 18.2.9  
Test date 4 April 2018

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration
Voltage applied to	Earth connected to	... x U <sub>0</sub>	kV	h
Conductor	Metal screen	4	48	4

### Requirement

No breakdown of the insulation shall occur.

### Result

The object passed the test.

## 4.10 Resistivity of semi-conducting screens

### Standard and date

Standard IEC 60502-2, subclause 18.2.10

Test date 26 April 2018

### Characteristic test data

Temperature during ageing 100 °C

Duration 7 x 24 h (14 to 21 March 2018)

Resistivity measured at 90 ± 2 °C

Item	Unit	Requirement	Measured/determined
Conductor screen			
• without ageing	Ωm	≤ 1000	34
• after ageing	Ωm	≤ 1000	37
Insulation screen			
• without ageing	Ωm	≤ 500	1
• after ageing	Ωm	≤ 500	1

### Result

The object passed the test.

## 5 NON-ELECTRICAL TYPE TESTS

### 5.1 Measurement of thickness of insulation

**Standard and date**

Standard IEC 60502-2, subclause 19.2

Test date 15 March 2018

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	-	5,5	-
Average	mm	-	-	5,49
Minimum [ $t_{min}$ ]	mm	$\geq 4,85$	-	5,27
Maximum [ $t_{max}$ ]	mm	-	-	5,61
$(t_{max} - t_{min}) / t_{max}$	-	$\leq 0,15$	-	0,06

**Result**

The object passed the test.

## 5.2 Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)

### Standard and date

Standard IEC 60502-2, subclause 19.3  
Test date 15 March 2018

### Oversheath

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	$\geq 1,4$	2,2	-
Average	mm	-	-	2,30
Minimum	mm	$\geq 1,56$	-	2,13

### Result

The object passed the test.



### 5.3 Tests for determining the mechanical properties of insulation before and after ageing

#### Standard and date

Standard IEC 60502-2, subclause 19.5  
 Test date 13 April 2018

#### Characteristic test data

Temperature during ageing  $135 \pm 3 \text{ }^\circ\text{C}$   
 Ageing duration 7 x 24 h (20 to 27 March 2018)

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	$\geq 12,5$	35,0
Elongation at break	%	$\geq 200$	627
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	-	33,7
variation	%	$\pm 25 \text{ max.}$	-4
Elongation at break			
value after ageing	%	-	643
variation	%	$\pm 25 \text{ max.}$	3

#### Result

The object passed the test.

## 5.4 Additional ageing test on pieces of completed cable

### Standard and date

Standard	IEC 60502-2, subclause 19.7
	IEC 60502-1, subclause 18.5
Test date	16 April 2018

### Characteristic test data

Temperature during ageing	100 ± 2 °C
Ageing duration	7 x 24 h (14 to 21 March 2018)

### Insulation

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	≥ 12,5	33,7
Elongation at break	%	≥ 200	643
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	-	31,8
variation	%	± 25 max.	-5
Elongation at break			
value after ageing	%	-	635
variation	%	± 25 max.	-1

### Oversheath

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	≥ 9,0	11,6
Elongation at break	%	≥ 125	147
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	≥ 9,0	12,3
variation	%	± 40 max.	6
Elongation at break			
value after ageing	%	≥ 100	165
variation	%	± 40 max.	12

### Result

The object passed the test.

## 5.5 Test on PVC insulation and sheaths at low temperature

### Standard and date

Standard IEC 60502-1, subclause 18.8

Test date 26 April 2018

### Characteristic test data

Temperature  $-15 \pm 2$  °C

Cooling time  $\geq 16$  h

Mass of hammer 1000 g

### Oversheath

Item	Unit	Requirement	Measured/determined
Cold elongation test	%	$\geq 20$	55
Cold impact test	-	No cracks	No cracks

### Result

The object passed the test.

## 5.6 Hot set test for XLPE insulation and elastomeric sheaths

### Standard and date

Standard IEC 60502-2, subclause 19.13  
Test date 20 March 2018

### Characteristic test data

Air temperature  $200 \pm 3$  °C  
Time under load 15 min  
Mechanical stress 20 N/cm<sup>2</sup>

### Insulation

Item	Unit	Requirement	Measured/determined
Elongation under load	%	$\leq 175$	71
Permanent elongation after cooling	%	$\leq 15$	-4

### Result

The object passed the test.

## 5.7 Water absorption test on insulation

### Standard and date

Standard IEC 60502-2, subclause 19.15

Test date 9 April 2018

### Characteristic test data

Temperature of water  $85 \pm 2 \text{ }^\circ\text{C}$

Duration 14 x 24 h (23 March to 6 April 2018)

Test method Gravimetric

### Insulation

Item	Unit	Requirement	Measured/determined
Increase of mass	mg/cm <sup>2</sup>	$\leq 1,00$	0,01

### Result

The object passed the test.

## 5.8 Flame spread on single cable

### Standard and date

Standard IEC 60502-2, subclause 19.16

Test date 13 April 2018

### Characteristic test data

Overall diameter of test piece 39 mm

Time for flame application 120 s

Flame type 1 kW pre-mixed flame

Complete cable	Unit	Requirement	Measured/determined
The distance between the lower edge of the top support and the onset of charring	mm	$\geq 50$	406
The distance between the lower edge of the top support and charring extends downwards to a point	mm	$\leq 540$	502

### Result

The object passed the test.

## 5.9 Shrinkage test for XLPE insulation

### Standard and date

Standard IEC 60502-2, subclause 19.18

Test date 30 March 2018

### Characteristic test data

Distance L between marks 200 mm

Temperature  $130 \pm 3$  °C

Duration 1 h

### Insulation

Item	Unit	Requirement	Measured/determined
Shrinkage	%	$\leq 4$	0,6

### Result

The object passed the test.

## 6 CHECK OF CABLE CONSTRUCTION

### Standard and date

Standard IEC 60502-2, clause 5-14

Test date 15 March 2018

Item	Unit	Requirement	Specified	Measured/determined
<b>Conductor</b>				
Diameter of conductor (d)	mm	$17,6 \leq d \leq 19,2$ <sup>1)</sup>	18,4 (nom.)	19,04
Number of wires	-	$\geq 34$	37	37
Diameter of wires	mm	-	3,02	2,98 (after compacting)
Swelling yarns applied	-	-	-	no
Resistance at 20 °C	$\Omega/\text{km}$	$\leq 0,0754$	-	0,0747
<b>Conductor screen</b>				
Diameter over conductor screen	mm	-	20	19,73
Thickness	mm	-	0,7 (nom.)	0,66
<b>Insulation</b>				
Diameter over insulation	mm	-	31	30,80
Thickness	mm	$\leq 4,85$	5,5 (nom.)	5,49
<b>Insulation screen</b>				
Diameter over insulation screen	mm	-	-	31,69
Thickness	mm	-	0,5 (nom.)	0,41
<b>Semi-conducting tape</b>				
Thickness x width of tape	mm	-	-	0,10 x 50
Overlap	%	-	-	20
<b>Metal screen</b>				
Number of Cu wires	-	-	43	43
Diameter of Cu wires	mm	-	0,86	0,83
Thickness x width of tape	mm	-	0,1 x 10	0,101 x 10,3
<b>PP Tape</b>				
Thickness x width of tape	mm	-	-	0,035 x 50
Overlap	%	-	-	14
<b>Oversheath</b>				
Diameter over layer	mm	-	38,6	38,66
Average thickness	mm	-	2,2 (nom.)	2,30
Minimum thickness	mm	$\leq 1,56$	-	2,13
Colour	-	-	red	red
Marking on the cable	Metal Cable CO. IEC 60502-2 CU/SC/XLPE/SC/SCT/(CWS+CT)/LSFOH(N2XSH) 1x240/25 SQMM 12/20(24)KV MADE IN IRAN 164-2 2017			
<sup>1)</sup> Dimensional limits do not have the status of a requirement but as a guideline only				

### Result

The object passed the test. The object has ST8 sheath, which is not covered by IEC 60502-2.



## 7 ADDITIONAL TESTS

### 7.1 Water absorption test on overshooth

#### Standard and date

Standard IEC 60502-1, subclause 18.13  
Test date 30 March 2018

#### Characteristic test data

Temperature of water  $70 \pm 2$  °C  
Duration 24 h (27 March 2018)  
Test method Gravimetric

#### Overshoot

Item	Unit	Requirement	Measured/determined
Increase of mass	mg/cm <sup>2</sup>	10	0,9

#### Result

The object passed the test.

## 7.2 Pressure test at high temperature on insulation and non-metal sheaths

### Standard and date

Standard IEC 60502-1, subclause 18.7  
Test date 5 April 2018

### Characteristic test data

Temperature  $80 \pm 2$  °C  
Heating time 6 h  
Mandrell diameter 34 mm  
Load 9 N

### Oversheath

Item	Unit	Requirement	Measured/determined
Depth of indentation	%	$\leq 50$	26

### Result

The object passed the test.

### 7.3 Flame spread test on bunched cables

**Standard and date**

Standard IEC 60332-3-24, Category C

Test date 10 April 2018

**Characteristic test data**

Flame application time 20 min

Number of burners 1

Item	Unit	Requirement	Calculated/measured
Total volume of non-metallic materials	l/m	1,5	0,83
Number of test pieces	-	$\geq 2$	2
Number of layers	-	$\geq 1$	1
Time to extinction of all burning or glowing	min	$\leq 60$	48
Extent of damage	m	$\leq 2,5$	0,55

**Result**

The object passed the test.

## 7.4 Smoke emission test

### Standard and date

Standard IEC 61034-2  
Test date 10 April 2018

### Characteristic test data

Number of cables 2

Item	Unit	Requirement	measured
Light transmittance	%	≥ 60	74,7

### Result

The object passed the test.

## 7.5 Tests for determining the mechanical properties of non-metal sheaths before and after ageing

### Standard and date

Standard IEC 60502-1, subclause 18.4  
 Test date 16 April 2018

### Characteristic test data

Temperature during ageing  $100 \pm 2 \text{ }^\circ\text{C}$   
 Ageing duration 7 x 24 h (23 to 30 March 2018)

### Oversheath

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	≥ 9,0	11,6
Elongation at break	%	≥ 125	147
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	≥ 9,0	12,0
variation	%	± 40 max.	4
Elongation at break			
value after ageing	%	≥ 100	173
variation	%	± 40 max.	17

### Result

The object passed the test.

## 7.6 Acid gas emission test

### Standard and date

Standard IEC 60754-1  
Test date 23 April to 8 May 2018

### Amount of halogen acid gas

HCl content of ..	Unit	Requirement	measured
Semi conductive tape	%	$\leq 0,5$	< 0,02
Semi conductive screens (mixed)	%	$\leq 0,5$	< 0,02
Insulation	%	$\leq 0,5$	< 0,02
PP tape	%	$\leq 0,5$	< 0,02
Oversheath	%	$\leq 0,5$	< 0,02

### Remarks

- No requirements for conformity are included in IEC 60754-1. Requirements taken from IEC 60502-1 table 23.
- The method specified in IEC 60754-1 is intended for type testing of individual components used in the cable construction. The use of this method will enable the requirements for individual components of a cable construction to be stated in the appropriate cable specification.

### Result

The object passed the test.

## 7.7 pH and conductivity test

### Standard and date

Standard IEC 60754-2  
Test date 23 April to 8 May 2018

### pH test

pH value of ..	Unit	Requirement	measured
Semi conductive tape	%	$\geq 4,3$	5,1
Semi conductive screens (mixed)	%	$\geq 4,3$	4,6
Insulation	%	$\geq 4,3$	5,3
PP tape	%	$\geq 4,3$	4,9
Oversheath	%	$\geq 4,3$	5,6

### Conductivity test

Conductivity of ..	Unit	Requirement	measured
Semi conductive tape	$\mu\text{S}/\text{mm}$	$\leq 10$	0,8
Semi conductive screens (mixed)	$\mu\text{S}/\text{mm}$	$\leq 10$	1,5
Insulation	$\mu\text{S}/\text{mm}$	$\leq 10$	0,5
PP tape	$\mu\text{S}/\text{mm}$	$\leq 10$	0,6
Oversheath	$\mu\text{S}/\text{mm}$	$\leq 10$	0,7

### Result

The object passed the test.

## 7.8 Fluorine content test

### Standard and date

Standard IEC 60684-2  
Test date 23 April to 8 May 2018

### Amount of fluorine

Fluorine content of ..	Unit	Requirement	Calculated/measured
Semi conductive tape	%	$\leq 0,1$	< 0,01
Semi conductive screens (mixed)	%	$\leq 0,1$	< 0,01
Insulation	%	$\leq 0,1$	< 0,01
PP tape	%	$\leq 0,1$	< 0,01
Oversheath	%	$\leq 0,1$	< 0,01

### Result

The object passed the test.



## 8 DATA SHEET

<b>METAL CABLE CO.</b>			
<b>DATA SHEET</b>			
No.: MC – 18641		Date : 3 May 2017	
Medium voltage cable		Acc. IEC 60502-2 , IEC 60332-1 , 12/20(24) KV	
CU / SC / XLPE / SC / SCT / (CWS+CT) / LSFOH			
Cable code : N2XSH			
R	<b>SPECIFICATION</b>		
1	Cable size	1x240 / 25 mm <sup>2</sup>	
2	Conductor	material	Plain annealed copper
		Class	2 , compacted round
		construction	37x3.02 mm
		Conductor dia.	18.5 mm
3	Conductor screen	material	Semi-conductive
		thickness	0.7 mm
4	Insulation	material	XLPE
		Operation temp.	90°C
		thickness	5.5 mm
		colour	Natural
5	Insulation screen	material	Semi-conductive
		thickness	0.5 mm
6	Metallic screen	material	Semi conductive tape + copper wire + copper tape
		Cross-section	25 mm <sup>2</sup>
7	Core wrap	material	PP tape
8	Outer jacket	material	LSFOH
		Operation temp.	90°C
		thickness	2.2 mm
		colour	Red
9	Overall diameter approx.	39.0 mm	
10	Cable weight approx.	3260 kg/km	
11	Cable length ( per drum )	1000 m	
12	Max. dc conductor resistance at 20°C	0.0754 Ω/km acc. IEC 60228	
13	Max. ac conductor resistance at 90°C	0.0965 Ω/km	
14	Partial discharge at 21 kv	5 PC	
15	Current rating in air 30 °C (flat touching)	647 A	
16	Current rating in ground at 20 °C (flat spaced)	470 A	
17	Short circuit current (conductor)	34.3 kA at 1 second	
18	High voltage test	42.0 kvac for 5 min	
19	Capacitance	0.30 µF/km	
20	Inductance ( tri-foil formation )	0.36 mH/km	
21	Flame retardant test	Acc. IEC 60332-1	
22	Flame retardant test	Acc. IEC 60332-3	
23	Smoke density test	Acc. IEC 61034	
24	Halogen free test	Acc. IEC 60754-2	
25	Min. bending radius	590 mm	
Marking : METAL CABLE CO. IEC 60502-2 N2XSH 1x240/25 RM 12/20 KV MADE IN IRAN 2017			

*Technical approval*

## 9 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
Dielectric tests and impulse current tests:	
peak value	≤ 3%
time parameters	≤ 10%
Capacitance measurement	0,3%
Tan δ measurement	± 0,5% ± 5 x 10 <sup>-5</sup>
Partial discharge measurement:	
< 10 pC	2 pC
10 to 100 pC	5 pC
> 100 pC	20%
Measurement of impedance AC-resistance measurement	≤ 1%
Measurement of losses	≤ 1%
Measurement of insulation resistance	≤ 10%
Measurement of DC resistance:	
1 to 5 μΩ	1%
5 to 10 μΩ	0,5%
10 to 200 μΩ	0,2%
Radio interference test	2 dB
Calibration of current transformers	2,2 x 10 <sup>-4</sup> I <sub>i</sub> /I <sub>u</sub> and 290 μrad
Calibration of voltage transformers	1,6 x 10 <sup>-4</sup> U <sub>i</sub> /U <sub>u</sub> and 510 μrad
Measurement of conductivity	5%
Measurement of temperature:	
-50 to -40 °C	3 K
-40 to 125 °C	2 K
125 to 150 °C	3 K
Tensile test	1%
Sound level measurement	type 1 meter as per IEC 60651 and ANSI S1,4,1971
Measurement of voltage ratio	0,1%